



## TEST REPORT

Page 1 of 1

Analysis No. : R26-1511

Report Date : 07/05/26

Received Date : 23/04/26

Analysis Date : 23-28/04/26

Customer : บริษัท โมน่า พาเนล (ประเทศไทย) จำกัด

Job No. : M/260062

Address : 44/19 หมู่ 7 ซอยสุขสวัสดิ์ 78 แยก 16 ถนนสุขสวัสดิ์  
แขวงบางจาก เขตพระประแดง จังหวัดสมุทรปราการ 10130

Sampling Date \* : 20/04/26

Sampling By \* : Customer

Contact : -

Type of Sample : Wastewater

Sample Conditions : 2604-WW0605 = white turbid

| Item | Parameter      | Unit | Method                                                  | Result                                                           | Standard | Analysis Date |
|------|----------------|------|---------------------------------------------------------|------------------------------------------------------------------|----------|---------------|
|      |                |      |                                                         | 2604-WW0605<br>น้ำทิ้งจากการใช้น้ำยา<br>ล้างแอร์รถยนต์ Air Verde |          |               |
| 1    | pH *           | -    | Electrometric Method (SM 4500 B)                        | 7.16                                                             | 5.5-9.0  | 23/04/26      |
| 2    | TSS            | mg/L | Dried at 103-105 °C (SM 2540 D)                         | 40.7                                                             | 60       | 24/04/26      |
| 3    | TDS *          | mg/L | Dried at 180 °C (SM 2540 C)                             | 154                                                              | -        | 27/04/26      |
| 4    | BOD *          | mg/L | 5-Days BOD Test, Azide Modification Method (SM 5210 B)  | 87.0                                                             | 100      | 23-28/04/26   |
| 5    | COD            | mg/L | Closed Reflux Titrimetric Method (SM 5220 C)            | 436                                                              | -        | 24/04/26      |
| 6    | Oil & Grease * | mg/L | Liquid-Liquid, Partition Gravimetric Method (SM 5520 B) | 6.5                                                              | 50       | 27/04/26      |

**Remarks** \* "Test marked "Not TISI Accredited" in this Report are not included in the TISI Accreditation Schedule for our Laboratory"

: BOD มีค่าปริมาณต่ำสุดที่สามารถรายงานเป็นตัวเลขได้ = 2 mg/L

COD มีค่าปริมาณต่ำสุดที่สามารถรายงานเป็นตัวเลขได้ = 40 mg/L

**Method** : SM = Standard Method for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24<sup>th</sup> Edition, 2023

**Standard** : Notification of the Ministry of Natural Resource and Environmental for Effluent Standard of Specific Type and Size of Building (2024) (B.E. 2567) ; Type ง.

Reviewed by

Ms. Wareerat Prachumdaeng  
Chief of Laboratory  
07/05/26



Approved by

Mrs. Porntip Pethshee  
Laboratory Manager  
07/05/26

END OF REPORT

- REPORTED RESULTS REFER TO SUBMITTED SAMPLE(S) ONLY
- DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL